

From: Devincentis, James M [jdevinc@entergy.com]
Sent: Tuesday, December 21, 2010 12:08 PM
To: Kim, James
Cc: Couture III, Philip
Subject: RE: G20100235/LTR-10-0175/EDATS: SECY-2010-0235 - Request for Licensee Comments on Proposed Director's Decision-Vermont Yankee Nuclear Power Station(TAC NO. ME3789

Jim K.

Our review identified a few minor items. None are significant. Your call on revising document.

Page 3

- GZ-3 is actually located approximately 70 ft from the Connecticut River. Actual distance depends on river stage.
- The highest reading from any monitoring well has been 2.52 million pci/L (measured on 2/8/2010) from monitoring well GZ-10.

Page 4

- On June 8, Entergy reported a leak in the reactor building (June 8 was the date that RHR relief valve leakage was discovered. This required a 4-hour notification to the NRC).

Page 6

- On March 23, 2010, Entergy installed an extraction well (GZ-EW1). (The well was installed on 3/23 and placed in service on 3/24).
- GZ-15 was utilized for groundwater extraction from July 28, 2010, until September 2, 2010 and again from October 28, 2010 until November 8, 2010.
- Entergy has pumped 307,000 gallons of groundwater...
- 298,000 gallons of water was shipped offsite for disposal... 9,000 gallons was returned to the station's liquid radioactive waste system for in-plant use. Evaluation of continued extraction is on-going.

Jim D.

From: Kim, James [<mailto:James.Kim@nrc.gov>]
Sent: Tuesday, November 30, 2010 2:27 PM
To: Devincentis, James M; Couture III, Philip
Subject: FW: G20100235/LTR-10-0175/EDATS: SECY-2010-0235 - Request for Licensee Comments on Proposed Director's Decision-Vermont Yankee Nuclear Power Station(TAC NO. ME3789

The proposed director's decision for the Congressman Hodes 2.206 is attached. If you have any comments, please provide them within 30 days of the issuance of the letter.

Thanks
Jim Kim

From: nrc_mail_1-1 Resource [mailto:nrc_mail_1-1.Resource@nrc.gov]
Sent: Tuesday, November 30, 2010 1:56 PM
To: Kim, James
Subject: G20100235/LTR-10-0175/EDATS: SECY-2010-0235 - Request for Licensee Comments on Proposed Director's Decision-Vermont Yankee Nuclear Power Station(TAC NO. ME3789

G20100235/LTR-10-0175/EDATS: SECY-2010-0235 - Request for Licensee Comments on Proposed Director's Decision-Vermont Yankee Nuclear Power Station(TAC NO. ME3789

ADAMS Accession: ML101250241

The attached document is being sent to you per your request to receive electronic mailings, if you wish to be removed follow the instructions below. The document is publicly available and will be accessible via the public web site Electronic Reading Room in the Agency Document Access and Management System (ADAMS), <http://www.nrc.gov/reading-rm/adams.html>, generally within six days. To access this document use the ADAMS number provided in this email.

Documents containing proprietary or safeguards information are not publicly available and will not be sent using the electronic mailing system.

You are currently subscribed to vermontyankee as: james.kim@nrc.gov .

To unsubscribe: Please go to the NRC's public website
<http://www.nrc.gov/public-involve/listserver/plants-by-region.html>

Once at the site, type in your e-mail address in the space provided and check the box(es) that correspond to the list(s) you would like to unsubscribe from. Then click the Unsubscribe button.

or send an email to lyris@nrc.gov with the following information in the subject line
unsubscribe vermontyankee james.kim@nrc.gov